

Commercial Radiator Thermostat Selection Guide



- *Approved combination, refer to notes for any restrictions/advice*
- 1 *Mount sensor horizontally*
- 2 *Consider use of remote sensor to improve performance*
- 3 *Remote sensor is recommended*
- 4 *Valve body flow selector must be commissioned*

Description	Built-in Sensors			Remote Sensors (0-2m)			2/5/8m Wall Adjusters
	Standard	Low Temp.	Tamperproof	Standard	Low Temp.	Tamperproof	
Symbol							
Model	RA2910	RA2914	RA2920	RA2912	RA2916	RA2922	RA5062, RA5065, RA5068
Codes	013G291000	013G291400	013G292000	013G291200	013G291600	013G292200	013G506200 013G506500 013G506800
Temp. Range	5-26°C	5-22°C	5-26°C	5-26°C	5-22°C	5-26°C	6-28°C

Valve Options						Sensor Options							
Symbol	Size	Standard Valves		Valves with pre-setting									
		Type	Code No.	Type	Code No.								
2-Pipe System	8/10mm	RA-FS 15	013G628300	N/A		• 4	• 4	• 4	• 4	• 4	• 4	• 4	
		RA-FS 15	013G628100	N/A									
		3/8"	RA-FN 10	013G002200	RA-N 10	013G003200							
		1/2"	RA-FN 15	013G002400	RA-N 15	013G003400							
		1/2"/15mm	RA-FN 15	013G008400	RA-N 15	013G0034AA	• 1	• 1	• 1	•	•	•	•
		3/4"	RA-FN 20	013G002600	RA-N 20	013G003600							
	1"	RA-FN 25	013G002800	RA-N 25	013G003800								
		3/8"	RA-FN 10	013G002100	RA-N 10	013G003100							
		1/2"	RA-FN 15	013G002300	RA-N 15	013G003300							
		1/2"/15mm	RA-FN 15	013G0023AA	RA-N 15	013G0033AA	• 2	• 3	• 2	•	•	•	•
		3/4"	RA-FN 20	013G002500	RA-N 20	013G003500							
	1"	RA-FN 25	013G002700	RA-N 25	013G003700								
	3/8"	RA-FN 10	013G014100	RA-N 10	013G015100								
	1/2"/15mm	RA-FN 15	013G014900	RA-N 15	013G015300	•	•	•	•	•	•	•	
	3/4"	RA-FN 20	013G014500	RA-N 20	013G015500								
1-Pipe System		1/2"	RA-G 15	013G338400	N/A								
		3/4"	RA-G 20	013G338600	N/A								
		1"	RA-G 25	013G338800	N/A								
		1/2"	RA-G 15	013G338300	N/A								
		3/4"	RA-G 20	013G338500	N/A								
		1"	RA-G 25	013G338700	N/A								

- *Approved combination, refer to notes for any restrictions/advice*
- 1 *Mount sensor horizontally*
- 2 *Consider use of remote sensor to improve performance*
- 3 *Remote sensor is recommended*
- 4 *Valve body flow selector must be commissioned*